



**MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027**



No.DHO/WZ/2025/D 966

Dated: 03/07/25

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter no DHOWZ/2020/2282 dated 28.12.2020 The school premises were re- inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

Name of the school: M/s AARYAN INTERNATIONAL SCHOOL

Address of School: OM VIHAR PH-1 ARYAN GARDEN UTTAM NAGAR ND-110059

Shifts: ONE Timing: MORNING


No. of Students: Boys: 974 Girls: 632 Total: 1606

No. of Staff (Teachers): Female: 82 Male: 25 Total: 107


That the accommodation provided for the class rooms as calculated.

1. (A) On floor space is sufficient Yes
(B) On Cubic space is sufficient Yes
2. That the classrooms are well ventilated Yes
3. That the classrooms are kept neat and clean Yes
4. That the classrooms are well lighted Yes
5. That the drinking water is wholesome Wholesome
6. That the latrines arrangement is adequate and there are sufficient latrines.
7. That urinals arrangement is adequate and there are sufficient urinals

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue.


IMRAN

H.O.S. / Principal
Aaryan International School
Om Vihar, New Delhi-110059
CBSE Affiliation No. 2730641


21/7/25

Dy. Health Officer
West Zone
Dy Health Officer
West Zone
MCD



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



Water sample collected from "Aaryan International School" Plot No.320, 321, Om Vihar, Phase-1A, Uttam Nagar, New Delhi – 110059 vide challan No- 45 Dated - 08.05.2025.
S1: Bore water at above site. S2: Drinking Point (RO) at above site.

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY.**

Particulars		Limit		S1	S2	
S. No.		Acceptable		Permissible		
PHYSICAL EXAMINATION						
1.	Date of collection	-----	--	--	27.05.25	27.05.25
2.	Date of Analysis	-----	--	--	29.05.25	29.05.25
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	2.0	1.2
6.	PH value	-----	6.5	8.5	7.40	6.70
7.	Electrical Conductivity	µmho/cm	--	--	2570	170
8.	Total dissolved solids	mg/l	500	2000	1670	110.5
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	510	22
11.	Total Hardness	mg/l	200	600	570	28
12.	Calcium Hardness	mg/l	--	--	190	16
13.	Magnesium Hardness	mg/l	--	--	380	12
14.	Calcium as Ca	mg/l	75	200	76	6.4
15.	Magnesium as Mg	mg/l	30	100	91.2	2.88
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	---	0.014	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	20.4	8.2
19.	Sulphate	mg/l	200	400	194	18
20.	Chloride	mg/l	250	1000	370	24
21.	Dissolved Iron	mg/l	1	N.R.	0.12	0.04
22.	Fluoride	mg/l	1	1.50	0.38	0.16
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	NIL	NIL
BACTERIOLOGICAL EXAMINATION						
25.	Coli-form per 100 ml at 37°C	MPN	0		44	0

REMARKS: As per tested parameters Sample S-1 can not be used for drinking purpose whereas Sample S-2 can be used for drinking purpose.

Siddhant
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

Siddhant
BACT.

Imran
A/CHEMIST

IMRAN
H.O.S. / Principal
Aaryan International School
Om Vihar, New Delhi-110059
CBSE Affiliation No. 2730641